Prince Edward Island
Clear
from the ground to the glass

Tel 902 368 5044
Toll free 1 866 368 5044
Fax 902 368 5830
www.gov.pe.ca/enveng

Communities, Land and Environment

Environment Division

PO Box 2000
Charlottetown
Prince Edward Island
Canada C1A 7N8

Town of North Rustico: Derek A French
PO Box 580
Cornwall, PE
Canada
C0A 1H0

Jun 21, 2016

Dear Client:

Please find on the Water Quality Test Report the laboratory test results for sample # P160620039 collected on 6/20/2016 from 116 Line Rd - Rte 269, North Rustico for Town of North Rustico: Derek A French.

Please note that the sample submission form was accompanied by the following information:

Well Location / Facility Name: North Rustico Sewer and Water Utility Corporation, North Rustico Water Distributi
Sample Point: kitchen tap
Notes:
Chlorine Residual: 0.39

The results of the analysis indicate:

For your information and interpretation.

Approved By:

J Schroeder

Julie Schroeder

Note: The results and interpretation contained in this report relate only to the parameters tested.

PEI Analytical Laboratories - Water Quality Test Report

23 Innovation Way, Charlottetown, PE

Standards Council of Canada
Accredited Laboratory
Scope of Accreditation 424

Conseil canadien des normes
Laboratoire accrédité
Portée d'accréditation 424

TM

Client Name: Town of North Rustico: Derek A French
Sample Location: 116 Line Rd - Rte 269, North Rustico
Date Sampled: June 20, 2016
Date Received: June 20, 2016

Sample Number: P160620039
Sampler: Allan Nisbet 628 7204
Water Type: Drinking Water

Water Microbiology Results

Method ID	Parameter	Results		Detection Limit
WML_01M*	Total Coliform	0	cfu/100 ml	0
WML_01M*	E. coli	0	cfu/100 ml	0
WML_01M*	Background Growth	0	cfu/ 100 ml	0

Approved By: Julie Schroeder

Date: Jun 21, 2016

Date of Analysis available upon request.

Allan 8/7/16

Legend: MPN = Most Probable Number
cfu/100 mls = colony forming units per 100 millilitres
* = method accredited by Standards Council of Canada;
Ammonia is equivelent to (Ammonia + Ammonium)-N
mg/L = milligrams per litre
nd = not detected; na = not analysed
< = less than

Results in this report relate only to those parameters tested. This report may not be reproduced except in full, without written approval from the laboratory.

End of Report